



November 18, 2021

Gary R. Bergstrom, Jr.  
Air Quality Program Supervisor  
Lincoln-Lancaster County Health Department  
3140 N Street  
Lincoln, NE 68510

Subject: DEC NSP Construction Permit Application, Source 00403

Dear Mr. Bergstrom:

Per conversations with my staff and your office, please accept the following amendments to our construction permit application, as amended on July 7, 2018. We are also emailing this request and will attach the application to that email. The amendments are necessary to clarify the operating conditions and requirements for the gas and oil-fired steam generators (boilers). The amendments also correct statements pertaining the fugitive emissions from the chiller units, and mailing/physical address updates.

Section 1 – General Information

- Part A – Please change the Company Address to 9445 Rokeby Rd, Lincoln, NE 68526.
- Part B – Please change the Facility Physical Address to 815 Pioneers Blvd.

Section 4 – Insignificant Activities


- Table 4-A – Please add the chillers to the list of insignificant activities.

Section 8 – Applicable Rules and Requirements

- Part B – Please add the following applicable regulation to the table:
  - Column 1 – NESHAP for Industrial, Commercial, and Institutional Boilers Area Sources
  - Column 2 – 40 CFR Part 63 Subpart JJJJJJ
  - Column 3 – EP-1, 2, 3, 4; 18.844 MMBtu/hr boilers: Will demonstrate compliance with NESHAP JJJJJJ by
    - Combusting only fuel oil that meets the specification of Ultra Low Sulfur Diesel
    - Completing boiler tune-ups as required
- Part B – Please remove the statement in column 3 pertaining to Subpart Dc indicating the boilers will only combust fuel oil during natural gas curtailment.

Thank you for your consideration of these changes. If you need additional information, please contact Dalton Johnson or Deb McGuire of my staff.

Sincerely,

A handwritten signature in black ink that reads "Jason L. Fortik". The signature is written in a cursive style with a large, looped "J" and a distinct "F".

Jason Fortik, P.E.  
DEC Administrator